

3

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 277

Date: 02/01/2023

It is certified that an inspection team headed by Satender Kumar
Assistant Engineer - 2000 U.P. (Rural) Azamgarh (Name of Officers
with designation) from U.P. Department of P.W.D. (Name of
Department/Office) inspected the Government A.P. School / J.P.
U.P. School Muzepur Azamgarh (Name & Address of
the School) on 02/01/2023 and found that the above the school
(Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 12 month

Signature with Seal

Name

Designation



To

02-01-2023
J.P.N.S. VIDYALAYA, MUZEPUR
Azamgarh

प्रधानाचार्य
जयप्रकाश नारायण सर्वोदय विद्यालय
मुसेपुर, आजमगढ़

District Water Analysis Laboratory

Ind G.D. U. P. JAB Nigam, Azamgarh

Drinking Water Sample Test Report

Report No. 277 (2022-23)

Date: 02/01/2023

Distt. 57 Azamgarh

Block palabani

Gram Panchayat Musepur

Revenue Village Musepur

Habitation main

Location J. N. S. Vidyalaya

H.P. Code -----

Musepur Azamgarh

Name & Designation of sample collector principal J. N. S. Vidyalaya, Musepur

Date & Time of Sampling 30/12/2022

Date of Analysis 02/01/2023

(A) CHEMICAL ANALYSIS	Unit	Test	Indian Standards	
			Acceptable	Cause of Rejection
	Mg/Lit.	Result		
1- Total dissolved solids	"		280 500	1500
2- Chloride (as Cl)	"		72 200	1000
3- Total Hardness (as CaCO ₃)	"		192 200	600
4- Alkalinity	"		178 200	600
(a) Phenolphtheline	"			
(b) Methyl Orange	"			
5- Sulphate	"		54 200	400
6- Nitrite (NO ₂) as Nitrite (NO ₂)			—	
7- Nitrate (NO ₃) as Nitrate (NO ₃)	"		16 45	45
8- Fluorides as F	"		0.2 1.0	1.5
9- Residual Chlorine	"		— 0.2	0.5
10- Iron as Fe	Mg/Lit.		0.1 0.1	1.0

(B) PHYSICAL EXAMINATION

	Unobjectionable	Objectionable
a- Taste	5	6 25
b- Colour		
c- Odour	Unobjectionable	Objectionable
d- Turbidity	NTU 1	4 10
e- pH	7.0 to 8.5	7.2 6.5 to 9.2

पेय जल गुणवत्ता

अन्तोपजनक/असन्तोपजनक



प्रधानाचार्य
जयप्रकाश नारायण सर्वोदय विद्यालय
मुलेपुर, आजमगढ़

Lab. Att.